

Aflæsning af vibrationsmålere

Dato: 16.07.2021 – uge 28

Placering af målere:

1. Læssøesgade 3
2. Ryesgade 9
3. Ryesgade 17
4. Plejecenteret Sølund, bygning 4

Ifølge gældende forsikringsselskab, er grænseværdien overholdt ved vibrationer under 3 mm/s.

Måler 1 - Læssøesgade 3:

Grænseværdien er ikke overskredet.

Måler 2 – Ryesgade 9:

Grænseværdien er ikke overskredet.





Måler 3 – Ryesgade 17:

Grænseværdien er ikke overskredet.

Måler 4 – Plejecenteret Sølund:

Grænseværdien er ikke overskredet.

Signaturforklaring:


-  = Vertikal vibration
-  = Langsgående vibration
-  = Tværgående vibration
-  = Markering af 3 mm/s

01 - 101302, Læssøesgade 3

! OFF Bars PNG Settings

Sensor: C22 #: 101302 Standard: (18B) DIN4150-3 Anlagte 25mm/s 1-315Hz Master(s) serial no.: 101302 Aggregate: Maximum
Unit: mm/s Latest calibration: 2021-05-07 Quantity: Velocity Interval time: 20 sec Aggregated time: 4 min Frequency weighting: OFF

Aggregation of data makes the different units presented unrelated and is not recommended for reporting when related units are needed




02 - 101363, Ryesgade 9

! OFF Bars PNG Settings

Sensor: C22 #: 101363 Standard: (18B) DIN4150-3 Anlagte 25mm/s 1-315Hz Master(s) serial no.: 101363 Aggregate: Maximum
Unit: mm/s Latest calibration: 2020-10-07 Quantity: Velocity Interval time: 20 sec Aggregated time: 4 min Frequency weighting: OFF

Aggregation of data makes the different units presented unrelated and is not recommended for reporting when related units are needed




03 - 102562, Ryesgade 17

! OFF Bars PNG Settings

Sensor: C22 #: 102562 Standard: (18B) DIN4150-3 Anlagte 25mm/s 1-315Hz Master(s) serial no.: 102562 Aggregate: Maximum
Unit: mm/s Latest calibration: 2019-12-10 Quantity: Velocity Interval time: 20 sec Aggregated time: 4 min Frequency weighting: OFF

Aggregation of data makes the different units presented unrelated and is not recommended for reporting when related units are needed



04 - 106147, Plejecenter Sølund

! OFF Bars PNG Settings

Sensor: C22 #: 106147 Standard: (18B) DIN4150-3 Anlagte 25mm/s 1-315Hz Master(s) serial no.: 106147 Aggregate: Maximum
Unit: mm/s Latest calibration: 2021-02-26 Quantity: Velocity Interval time: 20 sec Aggregated time: 4 min Frequency weighting: OFF

Aggregation of data makes the different units presented unrelated and is not recommended for reporting when related units are needed

